

# CERTIFICATE

## of constancy of performance

### 1922 - CPR - 0566

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Pillar fire hydrants**

**DN 80** (outlet flange size - 2.0"; Kv=117,739), **PN 10/16**;

**DN 100** (outlet flange size 2.5"; Kv=147,099), **PN 10/16**;

**DN 150** (outlet flange size 4.0"; Kv= 372,362; Kv= 367,429) **PN 10/16**

produced by

**YAKACIK VALF SAN. VE TİC. A.Ş.**

**Deri Organize San. Bölgesi, Tabak Sk., No:4, No.7-2 Özel Parsel,  
Tuzla, Istanbul, Türkiye**

and produced in the manufacturing plant of


**YAKACIK VALF SAN. VE TİC. A.Ş. Deri Organize San. Bölgesi, Tabak Sk.,  
No:4, No.7-2 Özel Parsel,  
Tuzla, Istanbul, Türkiye**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 14384:2005**

under system 1 were applied and that the products fulfil all the prescribed requirements set out above.

This certificate was first issued on 16.03.2016 and remains valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. This certificate should be reissued not later than 16.03.2020. The validity of this certificate can be verified in the CE register on [www.dedal-bg.net](http://www.dedal-bg.net).



Issued:  
Burgas, 01 March 2016

Manager:

**Dedal**  
Attestation &  
Certification

Arch. Galina Vasileva